

PRE-BID MEETING QUERIES, Dated 07.05.2018

IIIT SKLM/RGUKT-AP/E- Proc/Generator/RT12 /2018

**Bidder: Sri Srinivasa Agencies**

Page No	Clause	Query	Bidder question	Clarification
25	Annexure-II Point-7.0	Cabling system 3.5 Core Al. Armored cable 250 sq. mm As per site(app. 500mtrs)	25 Meters cable is enough	25meters is sufficient
26	Annexure-II Point-11	Exhaust system: Provision of M.S. pipe of suitable diameter (class B pipe) to <b>height 5mtr</b> above rooftop of eight room building (total appx 30 feet from the ground level).	Height 1 or 1.5 meter is enough	This will be decided during execution as per the expert opinion
26	Annexure-II Point-14	Clearance from various department.	Clearance certificate required from which department. (Whether CEIJ certificate Required From the electricity Department )	Clearance certificate from electricity department may be enclosed
32	Annexure-V	Free maintenance service from the date of commissioning.	Service will be provided. What about spare parts, Engine oil or other cost	Free service for a period of 5 Years from the date of commissioning including cost of spare parts, oil and any others required.

  
Administrative Officer (i/c),  
IIIT – Srikakulam

**Administrative Officer (I/C)**  
**IIIT SRIKAKULAM, RGUKT AP**  
**S.M PURAM-532 402.**  
**ETCHERLA (M), SRIKAKULAM (DL) A.P.**